



TORQUE AND LIMIT SWITCH OPERATION

SWITCH	CLOSE ←	INTERMEDIATE	→ OPEN
CLS 1-2			
CLS 1-3			
OLS 1-2			
OLS 1-3			
ACLS 1-2			
ACLS 1-3			
AOLS 1-2			
AOLS 1-3			

SYMBOL	DESCRIPTION	RATING
CLS	CLOSE LIMIT SWITCH	250VAC 10A
OLS	OPEN LIMIT SWITCH	250VAC 10A
ACLS	AUX. CLOSE LIMIT SWITCH	250VAC 16A
AOLS	AUX. OPEN LIMIT SWITCH	250VAC 16A
TP	THERMAL PROTECTOR	250VAC 15A

*EACH ACTUATOR SHOULD BE POWERED THROUGH IT'S OWN INDIVIDUAL SWITCH OR RELAY CONTACTS TO PREVENT CROSS FEED BETWEEN TWO OR MORE ACTUATORS.

PART NAME DC WIRING DIAGRAM STANDARD

DWG. NO HQ-8420-A

DATE 2006.06.02 ISSUE REF: A

HQ-008

APPLICATION



RAM UNIVERSAL LTD.
Unit 20
Cottage Lane Industrial Estate
Broughton Astley
Leicestershire
United Kingdom, LE9 6TU
T: +44 (0)1455 285428
F: +44 (0)1455 285404
W: ramuniversal.co.uk

DOC : WD-01 1-09-2008